

 <p>Berkeley PUBLIC SCHOOLS Berkeley Unified School District</p>	ADDENDUM #2
	Thousand Oaks Fire Alarm Project
	Date: July 1, 2024

ADDENDUM TO BID DOCUMENTS

The following clarifications are provided based on questions received or changes in District requirements and must be added/considered when completing your submittal:

Acknowledgement of receipt of this *ADDENDUM* is required in the bid form. Please clearly note the addendum date and number.

CLARIFICATIONS:

- 1) The Architects for this project (Hibser Yamauchi Architects) have reviewed the current scope of work and drawings and have made the determination that the work can be performed as described in the drawings, while the school campus is active.
NO ALTERNATE WILL BE ADDED TO THE BID PACKAGE.
 See below for further clarification:

- a) Work will need to be performed by section and changed over in phases.
 "Provide and install new notifier voice evacuation fire alarm system as shown on plans and cross-connect to existing system until new system is installed."
 (FA0.01 & FA0.02)

- 2) Proposals are still due July 10, 2024 by 2:00 PM as described in Addendum #1. **The RFI deadline has been extended and is as follows:**

- a) **July 2, 2024 by 5:00PM - all RFI's must be submitted to capitalprojects@berkeley.net**

END OF ADDENDUM #02